

ITEM	QTY.	DESCRIPTION
1	4	1/2" PLUG SOLID F.C. STL. THRD.
2	2	1/2" TEE 3000#, 304 S.S. THRD.
3	2	1/2" X 4" LG. PIPE NIPPLE SCH. 80S 304 S.S. SEAMLESS, THRD.
5	2	1/2" GLOBE VA. 316 STAINLESS STL. HEX NO. HN-491-1U3331411 OR EQUAL.
6	6	3/8" O.D. X 1/2" MALE CONN. 316 S.S. SWAGELOCK
7	1	3-VALVE MANIFOLD FURN. WITH TRANS.
8	*	3/8" O.D. X .035" WALL TUBING 316 S.S.
9	2	3/8" O.D. TUBE TEE 316 S.S. SWAGELOCK
10	1	FLOOR MOUNT O'BRIEN #F-52 OR EQUAL

* DETERMINE IN FIELD

LEGEND
L-LOW
H-HIGH


INTEGRAL CONTROL SYSTEM SERVICES, INC.

 1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-6900 Fax: 330-923-2116

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

AutoCAD NAME: FLOWTRANS1.dwg

APPROVED BY	DATE	DRAWING NO.	PART NO.
THIS SHEET ALSO USED FOR			


 3rd ANGLE PROJECTION
 DO NOT SCALE DRAWING

QTY.	LINE NUMBER(S)	MANUFACTURER/DESCRIPTION	PART (MODEL) #
			042601-1

DES. BY	DET. BY	TITLE
LA	MM	INSTRUMENT PIPING DETAIL FLOW TRANSMITTER
DATE	SCALE	DIVISION:
	NONE	PLANT:
		LOCATION/ACTIVITY: