



BASEMENT EL. 0'-0"
BOILERS 1&2

CONTINUED ON LTV03 SHEET 4

INST TAG NUMBER	ITEM	ELEVATION	MOUNTING	SERVICE
SI-123	SPEED INDICATOR	5'-0"	EXISTING	ID FAN TACH
SI-223	SPEED INDICATOR	5'-0"	EXISTING	ID FAN TACH
SI-124	SPEED INDICATOR	5'-0"	EXISTING	FD FAN TACH
SI-224	SPEED INDICATOR	5'-0"	EXISTING	FD FAN TACH
FV-103	FLDW VALVE	5'-0"	EXISTING	ID FAN TURBINE
FV-105	FLDW VALVE	5'-0"	EXISTING	FD FAN TURBINE
FV-203	FLDW VALVE	5'-0"	EXISTING	ID FAN TURBINE
FV-205	FLDW VALVE	5'-0"	EXISTING	FD FAN TURBINE
AI-152	OPACITY ANALYZER	12'-0"	EXISTING	BOILER EXIT OPACITY
AI-252	OPACITY ANALYZER	12'-0"	EXISTING	BOILER EXIT OPACITY
FT-106	FLDW TRANSMITTER	5'-0"	EXISTING	FEEDWATER FLDW
FT-206	FLDW TRANSMITTER	5'-0"	EXISTING	FEEDWATER FLDW
CD-209	CONTROL DRIVE	0'-0"	EXISTING	BFG CONTROL VALVE
CD-109	CONTROL DRIVE	0'-0"	EXISTING	BFG CONTROL VALVE
ZS-240-1	POSITION LIMIT SWITCH	5'-0"	EXISTING	BFG VALVE OPEN/CLOSED
ZS-140-1	POSITION LIMIT SWITCH	5'-0"	EXISTING	BFG VALVE OPEN/CLOSED
FT-416	DP TRANSMITTER	5'-0"	PM 2	RAW WATER TO SOFTNER
FT-419	DP TRANSMITTER	5'-0"	PM 2	CITY WATER FLDW
PT-405	PRESSURE TRANSMITTER	5'-0"	PM 2	PLANT AIR PRESSURE
PT-406	PRESSURE TRANSMITTER	5'-0"	PM 2	INSTRUMENT AIR PRESS
PT-417	PRESSURE TRANSMITTER	5'-0"	PM 2	BOILER FEED PUMP SUCTION
PT-418	PRESSURE TRANSMITTER	5'-0"	PM 2	CITY WATER PRESSURE

NOTES:

- ① WM- WALL MOUNTED
- ② PM- PIPE STAND MOUNTED
- ③ RM- RACK MOUNTED

AutoCAD NAME: .dwtg

INTEGRAL CONTROL SYSTEM SERVICES, INC.
ICSS 1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-6900 Fax: 330-923-2118

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE HARMFUL TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

APPROVED BY: _____ DATE: _____

DRAWING NO. _____ PART NO. _____

THIS SHEET ALSO USED FOR _____

DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED:
 MILLIMETRES INCHES
 1 PLACE ± 0.3 mm 2 PLACE ± .01
 2 PLACE ± 0.003 mm 3 PLACE ± .001
 3 PLACE ± 0.015 mm 4 PLACE ± .0005

3rd ANGLE PROJECTION
 DO NOT SCALE DRAWING

QTY		LINE NUMBER(S)	MANUFACTURER/DESCRIPTION	PART (MODEL) #
PART NO.				
DES. BY	LA	DET. BY	MM	TITLE
CHECKED BY		SAFETY OK		I&C INSTALLATION STEEL MILL # 4
DATE		SCALE		DIVISION:
				PLANT:
				LOCATION/ACTIVITY: